



Czech

INSPECTION CERTIFICATE

File number **14.984.832 -3**

Issued according to EN ISO/IEC 17020 to the organization:

inChaNet s.r.o.
Hasičská 3019, 756 61, Rožnov pod Radhoštěm, Czech Republic

On the basis of results conducted on 27.2.2023, which are listed under Inspection Report of TÜV SÜD Czech file No.: 14.984.832-1 and 14.984.832-2 we hereby confirm conformity of the below mentioned device:

Name:	Smart public charger for two vehicles
Type:	CHARGING COLUMN INCHANET 2x22kW
Serial number:	S220011 (2022806)
Power voltage:	3 x 360-440 V AC
Frequency:	50 Hz
Input Current max:	3 x 63 A
Output Power:	2 x 22 kW (32 A max)
Protect class	Class I
Protect cover:	IP65 body (IP44 Plugs)
Dimension:	1300 x 200 x 150 mm
Environmental characteristics:	Outdoor/indoor use
Manufacturer:	inChaNet s.r.o.

With requirements:

ČSN EN IEC 61851-1 ed.3:2020 and ČSN EN 61851-22: 2002 and related standards, which are mentioned in Inspection Reports no. 14.984.832-1 and 14.984.832-2.

Valid conditions:

The outcomes of inspection presented in the inspection report are related only to the inspected device; the results are presented in Inspection Report 14.984.832-1 and 14.984.832-2.

In Veprnice, on 27.2.2023



On behalf of TÜV SÜD Czech s.r.o. : **Petr Domša, Ph.D.**