



Czech

INSPECTION CERTIFICATE

File number **15.857.415 -3**

Issued according to EN ISO/IEC 17020 to the organization:

inChaNet s.r.o.
Hasičská 3019, 756 61, Rožnov pod Radhoštěm, Czech Republic

On the basis of results conducted on 28.2.2024, which are listed under Inspection Report of TÜV SÜD Czech file No.: 15.857.415-1 and 15.857.415-2 we hereby confirm conformity of the below mentioned device:

Name:	CUBISH PORTABOX BASIC
Serial number:	2406000002
Power voltage:	3x 360 – 440 VAC
Frequency:	50 Hz
Input current max.:	3 x 32 A
Output power:	22 kW, 32 A max
Protection class:	Class I
Protect cover:	IP 54
Manufacturer:	inChaNet s.r.o.

With requirements:

ČSN EN IEC 61851-1 ed.3:2020 and ČSN EN 61851-22: 2002 and related standards, which are mentioned in Inspection Reports no. 15.857.415-1 and 15.857.415-2.

Valid conditions:

The outcomes of inspection presented in the inspection report are related only to the inspected device; the results are presented in Inspection Report 15.857.415-1 and 15.857.415-2.

In Vejpnice, on 27.3.2024

On behalf of TÜV SÜD Czech s.r.o. : **Petr Domša, Ph.D.**

